

Particle Filtration Efficiency (PFE) and Differential Pressure (Delta P) Final Report

Report No. PFE20210127-01 Page 1 of 2

Sponsor

It is being developed under the Misumi brand.

Address Study Number

192036-501

Testing Date Expired Date 27 January 2021 26 January 2022

Testing Facility

RUEE, Research Unit of Applied Electric Field in Engineering

Test Procedure

ASTM F2299-03

Summary: This procedure was performed to evaluate the non-viable particle filtration efficiency of the test article. Polystyrene Latex (PSL) were nebulized Poly-dispersedly and passed through the test article. The test procedure measures filtration efficiency by comparing between the particle concentration count in the upstream and the downstream ones.

Filtered and dried air is passed through an atomizer to produce an aerosol containing suspended latex spheres. This aerosol is then passed through a charge neutralizer. The aerosol is then mixed and diluted with additional preconditioned air to produce a stable, neutralized, and dried aerosal of latex spheres.

One-minute particle concentration count were performed, with and without the test article in the system. The filtration efficiency was calculated using the average number of particles penetrating the test article compared to the average of the control values.

Area of Test: 12.57 cm²
Particle Size: 0.1 µm
Face Velocity: 10.6 cm/s

Environment: 22 ±5°C and 48 ±5% relative humidity (RH) for 4 hours

References: TSI Classifier Model 3082 S/N: 3082001807003,

TSI CPC Model 3788 5/N: 3788180801,

TSI Manometer Model 8380 S/N: T83801703012

Average Filtration Efficiency: 99.62%

Test Article Number	Upstream Counts (particles/cm²)	Downstream Counts (particles/cm²)	Filtration Efficiency
1	1,140.00	4.16	99.64%
2	1,180.00	4.36	99.63%
3	1,100.00	4.28	99.61%
4	1,120.00	4.14	99.63%
5	1,150.00	4.77	99.59%

Study Director Assoc. Prof. Dr. Panich Intra

27-Jan-2021

Study Completion Date

^{*}Counterfeiting test report whether it is a whole/part or using a counterfeiting report in any term is an offense under the criminal code.*

Tested and Reported by: Research Unit of Applied Electric Field in Engineering (NEEE), 88 Mo. 8. Reports, Diseases, Chang May 50220, Tested (NEEE) (NEEE)

Document Designed by: Dytrugge Milproper, Head of Information Resource Control Department, Research Unit of Applied Electric Field in Engineering FIEED) (New 5



Particle Filtration Efficiency (PFE) and Differential Pressure (Delta P) Final Report

Report No. PFE20210127-01 Page 2 of 2

Test Article Number	Delta P (mmH₂O)	Delta P (mmH ₂ O/cm²)	Delta P (Pa/cm²)
1	43.63	3.47	34.04
2	43.94	3.50	34.28
3	43.08	3.43	33.61
4	43.68	3.47	34.08
5	43.12	3.43	33,64

*** End of Report ***

Statement:

- This report is considered invalid without approved signature;
- The articles and article information was/were provided by the sponsor who should be responsible for the authenticity with RUEE hasn't verified;
- 3. The results shown in this report refer(s) only to the articles tested;
- Without written approval of RUEE, this report can't be reproduced except in their entirely.

Reference Note:

Disposable Hygienic Carbon Mask 4PLY



27-Jan-2021

Study Director Assoc. Prof. Dr. Panich Intra

Study Completion Date